



## **Declaration of Conformity**

For the following equipment	For t	the	follo	wing	equi	pment	
-----------------------------	-------	-----	-------	------	------	-------	--

Product Name: Din-Rail Switching Power Supply

Model Designation: DRA-x-y (x=40,60; y=12,24); DRC-xy (x=40,60; y=A,B),DRA-60-12BM

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

## RoHS Directive (2011/65/EU)

## Low Voltage Directive (2014/35/EU):

EN60950-1:2006+A11+A1+A12+A2 TUV certificate No: R50289105

# Electromagnetic Compatibility Directive (2014/30/EU):

#### **EMI (Electro-Magnetic Interference)**

Conducted emission / Radiated emission

	EN55032:2015		Class B				
Harmonic current	EN61000-3-2:2014						
Voltage flicker	EN61000-3-3:2013						
EMS (Electro-Magnetic Susceptibility)							
EN55024:2010+A1:2015	EN61204-3:2000						
ESD air	EN61000-4-2:2009	Level 3	8KV				
ESD contact	EN61000-4-2:2009	Level 2	4KV				
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 2	3V/m				
EFT bursts	EN61000-4-4:2012	Level 2	1KV/5KHz				
Surge susceptibility	EN61000-4-5:2014	Level 3	1KV/Line-Line				
Surge susceptibility	EN61000-4-5:2014	Level 3	2KV/Line-Earth				

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

EN61000-4-6:2014

EN61000-4-8:2010

This Declaration is effective from serial number EB7xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

Conducted susceptibility

Magnetic field immunity

Voltage dip, interruption

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification Center: (Signature)

(Name / Position)

Ted Cheng/Director, Sales Dept. :

(Name / Position)

Level 3

Level 4

EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods

3V

3A/m

(Signature)

Taiwan

Feb. 9th, 2017

(Place)

(Date)